

NPDES Permit No. IL0063525

Notice No. GY:24050101.GY

Public Notice Beginning Date: June 07, 2024

Public Notice Ending Date: July 9, 2024

National Pollutant Discharge Elimination System (NPDES)  
Permit Program

PUBLIC NOTICE/FACT SHEET  
of  
Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois EPA  
Division of Water Pollution Control  
Permit Section  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, Illinois 62794-9276  
217/782-0610

Name and Address of Permittee:

Lincoln Recovery  
19067 West Frontage Road  
Raymond, Illinois 62560

Name and Address of Facility:

Lincoln Recovery STP  
19067 West Frontage Road  
Raymond, Illinois 62560  
(Montgomery County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES Permit to discharge into the waters of the state and has prepared a draft Permit and associated fact sheet for the above named Permittee. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. All comments on the draft Permit and requests for hearing must be received by the IEPA by U.S. Mail, carrier mail or hand delivered by the Public Notice Ending Date. Interested persons are invited to submit written comments on the draft Permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the Permit applicant. The NPDES Permit and notice numbers must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft Permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft Permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final Permit is issued. For further information, please call Getie Yilma at 217/782-0610.

The following water quality and effluent standards and limitations were applied to the discharge:

Title 35: Environmental Protection, Subtitle C: Water Pollution, Chapter I: Pollution Control Board and the Clean Water Act were applied in determining the applicable standards, limitations and conditions contained in the draft Permit.

The applicant is engaged in treating domestic wastewater for the Carlinville Magnuson Grand Hotel.

The length of the Permit is approximately 5 years.

The main discharge number is 001. The seven day once in ten year low flow (7Q10) of the receiving stream, Shop Creek tributary to Shoal Creek is 0 cfs.

The design average flow (DAF) for the facility is 0.026 million gallons per day (MGD) and the design maximum flow (DMF) for the facility is 0.033 MGD. Treatment consists of a 2-cell aerated lagoon with rock filter and chlorine contact chamber.



**DRAFT**

**JUN 07 2024**

**Public Noticed**

The discharge(s) from the facility is (are) proposed to be monitored and limited at all times as follows:

Discharge Number(s) and Name(s): 001 STP Outfall

Load limits computed based on a design average flow (DAF) of 0.026 MGD (design maximum flow (DMF) of 0.041 MGD).

The effluent of the above discharge(s) shall be monitored and limited at all times as follows:

Parameter	LOAD LIMITS lbs/day			CONCENTRATION LIMITS mg/L			Regulation			
	Monthly Average	Weekly Average	Daily Maximum	Monthly Average	Weekly Average	Daily Maximum				
CBOD <sub>5</sub> **	2.2 (2.8)		4.3 (5.5)	10		20	35 IAC 304.120 40 CFR 133.102			
Suspended Solids**	2.6 (3.3)		5.2 (6.6)	12		24	35 IAC 304.120 40 CFR 133.102			
pH	Shall be in the range of 6 to 9 Standard Units						35 IAC 304.125			
Fecal Coliform	Daily Maximum shall not exceed 400 per 100 mL						35 IAC 304.121			
Chlorine Residual							0.05	35 IAC 302.208		
Ammonia Nitrogen:								35 IAC 355 and 35 IAC 302		
March-May/Sept.-Oct.	0.35 (0.44)	0.87 (1.1)	1.3 (1.6)	1.6	4.0	5.8				
June-August	0.33 (0.41)	0.82 (1.1)	2.0 (2.5)	1.5	3.8	9.1				
Nov.-Feb.	0.87 (1.1)		1.4 (1.8)	4.0		6.4				
				Monthly Avg. not less than	Weekly Avg. not less than	Daily Minimum				
Dissolved Oxygen										
March-July							N/A	6.0	5.0	35 IAC 302.206
August-February							5.5	4.0	3.5	

\*Load Limits are calculated by using the formula:  $8.34 \times (\text{Design Average and/or Maximum Flow in MGD}) \times (\text{Applicable Concentration in mg/L})$ .

\*\*BOD<sub>5</sub> and Suspended Solids (85% removal required): In accordance with 40 CFR 133, the 30-day average percent removal shall not be less than 85 percent.

This draft Permit also contains the following requirements as special conditions:

1. Reopening of this Permit to include different final effluent limitations.
2. Operation of the facility by or under the supervision of a certified operator.
3. Submission of the operational data in a specified form and at a required frequency at any time during the effective term of this Permit.
4. More frequent monitoring requirement without Public Notice.
5. Prohibition against causing or contributing to violations of water quality standards.
6. Recording the monitoring results on Discharge Monitoring Report Forms using one such form for each outfall each month and submitting the forms to IEPA each month.
7. The provisions of 40 CFR Section 122.41(m) & (n) are incorporated by reference.
8. Effluent sampling point location.
9. Reopening of this Permit to include revised effluent limitations based on a Total Maximum Daily Load (TMDL) or other water quality study.